

FIRE PROTECTION
DEMOLITION NOTES:

- A. DEMOLITION DRAWINGS ARE DIAGRAMMATIC ONLY AND ARE BASED ON FIELD OBSERVATION AND EXISTING RECORD DRAWINGS. CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS PRIOR TO BEGINNING WORK AND NOTIFY THE ARCHITECT/ENGINEER OF ANY DISCREPANCIES BETWEEN THE "AS-BUILT" CONDITIONS AND THESE DRAWINGS.
- B. THIS CONTRACTOR IS RESPONSIBLE FOR REMOVAL AND RE-INSTALLING OF EXISTING CEILING TILE NOT REMOVED BY THE GENERAL CONTRACTOR FOR THE DEMOLITION OF EXISTING FIRE PROTECTION PIPING, SPRINKLER HEADS, EQUIPMENT, ETC. VERIFY WITH ARCHITECTURAL PLANS FOR CEILING WORK BY THE GENERAL CONTRACTOR. ANY CEILING TILE OR GRID DAMAGED DURING CONSTRUCTION SHALL BE REPLACED WITH NEW BY THIS CONTRACTOR.
- C. THIS CONTRACTOR SHALL OPEN ALL WALLS AND/OR CEILINGS FOR DEMOLITION OF EXISTING FIRE PROTECTION PIPING, SPRINKLER HEADS, EQUIPMENT, ETC. AS REQUIRED.
- D. THIS CONTRACTOR IS RESPONSIBLE FOR PATCHING ALL HOLES/WALLS AND OR CEILINGS FROM DEMOLISHED FIRE PROTECTION PIPING, SPRINKLER HEADS, EQUIPMENT, ETC. IN FLOORS, WALLS, AND CEILINGS TO MATCH EXISTING.
- DISCONNECT AND REMOVE EXISTING SPRINKLER PIPING. PREPARE REMAINING PIPING AND SPRINKLER HEADS FOR RE-CONNECTION.
- DISCONNECT AND REMOVE EXISTING ZONE VALVE WITH SUPERVISORY SWITCH, FLOW SWITCH, AND TEST AND DRAIN VALVE. PREPARE REMAINING PIPING FOR RE-CONNECTION. THE EXISTING ZONE VALVE & SUPERVISORY SWITCH SHALL BE SAVED FOR RE-INSTALLATION.

GENERAL NOTES:

1. THE GENERAL CONTRACTOR IS REMOVING CEILING TILE AND GRID IN AREAS OF PIPE REPLACEMENT, RELOCATE AND REINSTALL EXISTING CEILING DIFFUSERS AND ALL GRILLES AS REQUIRED FOR WORK. SEE ARCHITECTURAL DRAWINGS FOR CEILING WORK.
2. ALL SPRINKLER MAINS BEING REMOVED SHALL BE REPLACED WITH THE SAME SIZE PIPE. SEE NEW PLANS FOR MAIN SIZES.

PHASING NOTES:

1. CONTRACTOR SHALL REPLACE SPRINKLER PIPING IN ALL AREAS DURING WEEKEND OR OVERTIME HOURS. WORK SPACES SHALL BE LEFT CLEAN AND USABLE BY THE END OF EACH SHIFT TO ALLOW STAFF USE OF AREAS DURING NORMAL BUSINESS HOURS. WORK IN MECHANICAL SPACES MAY BE COMPLETED DURING NORMAL BUSINESS HOURS.
2. COMPLETE WORK ON ONE SPRINKLER ZONE AT A TIME ON EACH FLOOR. THE SYSTEM SHALL BE FILLED BY THE END OF EACH SHIFT IN ORDER TO MAINTAIN AN OPERATIONAL SYSTEM AT THE CONTRACTOR'S OPTION. FIRE WATCH SHALL BE MAINTAINED BY THE CONTRACTOR FOR NON-OPERATIONAL ZONES FOR SHORT PERIODS OF TIME IN ORDER TO EXPEDITE WORK IN CERTAIN AREAS.
3. REFER TO INDIVIDUAL PLAN NOTES FOR PHASING OF CRITICAL AREAS.

1 BASEMENT FIRE PROTECTION DEMOLITION PLAN
FPI 1/16"=1'-0"




Dept. of Veterans Affairs
Medical Center
2101 Elm Street North
Fargo, ND 58102

IMAGE GROUP
IMAGE GROUP INC.
403 CENTER AVENUE, SUITE 300
MOORHEAD, MN 56560

ONE
BUILDING SYSTEM CONSULTANTS
Fargo, ND • Grand Forks, ND • Alexandria, MN
701.280.0100 • 701.775.3394 • 320.846.0100

IMAGE GROUP INC., Architecture & Interiors
OBERMILLER NELSON ENGINEERING, Mechanical Engineers
MBN ENGINEERING, Electrical Engineers



Drawing Title
BASEMENT
FIRE PROTECTION
DEMOLITION PLAN

VA Project No.
437-13-105

Contract No.
VA263-P-1217
VA263-C-

Building No.
1, 9, 46

AutoCAD File Name
2012227-FP-1dwg

Project Title
FARGO VA HEALTH CARE SYSTEM
REPLACE SELECTED SPRINKLER MAINS PHASE 2

Designed By
JP

Checked By
JP

Drawn By
NH

Location
FARGO VA HEALTH CARE SYSTEM
FARGO, ND

Date
February 5, 2013

Drawing No.
FP1

Dwg. 8 of 16

Department of
Veterans Affairs



FIRE PROTECTION
DEMOLITION NOTES:

- A. DEMOLITION DRAWINGS ARE DIAGRAMMATIC ONLY AND ARE BASED ON FIELD OBSERVATION AND EXISTING RECORD DRAWINGS. CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS PRIOR TO BEGINNING WORK AND NOTIFY THE ARCHITECT/ENGINEER OF ANY DISCREPANCIES BETWEEN THE "AS-BUILT" CONDITIONS AND THESE DRAWINGS.
- B. THIS CONTRACTOR IS RESPONSIBLE FOR REMOVAL AND RE-INSTALLING OF EXISTING CEILING TILE NOT REMOVED BY THE GENERAL CONTRACTOR FOR THE DEMOLITION OF EXISTING FIRE PROTECTION PIPING, SPRINKLER HEADS, EQUIPMENT, ETC. VERIFY WITH ARCHITECTURAL PLANS FOR CEILING WORK BY THE GENERAL CONTRACTOR. ANY CEILING TILE OR GRID DAMAGED DURING CONSTRUCTION SHALL BE REPLACED WITH NEW BY THIS CONTRACTOR.
- C. THIS CONTRACTOR SHALL OPEN ALL WALLS AND/OR CEILINGS FOR DEMOLITION OF EXISTING FIRE PROTECTION PIPING, SPRINKLER HEADS, EQUIPMENT, ETC. AS REQUIRED.
- D. THIS CONTRACTOR IS RESPONSIBLE FOR PATCHING ALL HOLES/WALLS AND OR CEILINGS FROM DEMOLISHED FIRE PROTECTION PIPING, SPRINKLER HEADS, EQUIPMENT, ETC. IN FLOORS, WALLS, AND CEILINGS TO MATCH EXISTING.
- DISCONNECT AND REMOVE EXISTING SPRINKLER PIPING. PREPARE REMAINING PIPING AND SPRINKLER HEADS FOR RE-CONNECTION.
- DISCONNECT AND REMOVE EXISTING ZONE VALVE WITH SUPERVISORY SWITCH, FLOW SWITCH, TEST AND DRAIN VALVE, AND SIGHT GLASS. PREPARE REMAINING PIPING FOR RE-CONNECTION. THE EXISTING ZONE VALVE & SUPERVISORY SWITCH SHALL BE SAVED FOR RE-INSTALLATION.
- WORK IN OUTLINED AREA REMOVED UNDER DEDUCT ALTERNATE NO. 1.

GENERAL NOTES:

1. THE GENERAL CONTRACTOR IS REMOVING CEILING TILE AND GRID IN AREAS OF PIPE REPLACEMENT. RELOCATE AND REINSTALL EXISTING CEILING DIFFUSERS AND ALL GRILLES AS REQUIRED FOR WORK. SEE ARCHITECTURAL DRAWINGS FOR CEILING WORK.
2. ALL SPRINKLER MAINS BEING REMOVED SHALL BE REPLACED WITH THE SAME SIZE PIPE. SEE NEW PLANS FOR MAIN SIZES.

PHASING NOTES:

1. CONTRACTOR SHALL REPLACE SPRINKLER PIPING IN ALL AREAS DURING WEEKEND OR OVERTIME HOURS. WORK SPACES SHALL BE LEFT CLEAN AND USABLE BY THE END OF EACH SHIFT TO ALLOW STAFF USE OF AREAS DURING NORMAL BUSINESS HOURS. WORK IN MECHANICAL SPACES MAY BE COMPLETED DURING NORMAL BUSINESS HOURS.
2. COMPLETE WORK ON ONE SPRINKLER ZONE AT A TIME ON EACH FLOOR. THE SYSTEM SHALL BE FULLED BY THE END OF EACH SHIFT IN ORDER TO MAINTAIN AN OPERATIONAL SYSTEM. AT THE CONTRACTOR'S OPTION, FIRE WATCH SHALL BE MAINTAINED BY THE CONTRACTOR FOR NON-OPERATIONAL ZONES FOR SHORT PERIODS OF TIME IN ORDER TO EXPEDITE WORK IN CERTAIN AREAS.
3. REFER TO INDIVIDUAL PLAN NOTES FOR PHASING OF CRITICAL AREAS.

1 FIRST FLOOR FIRE PROTECTION DEMOLITION PLAN
FP2 1/16"=1'-0"



Dept. of Veterans Affairs
Medical Center
2101 Elm Street North
Fargo, ND 58102




IMAGE GROUP INC.
403 CENTER AVENUE, SUITE 300
MOORHEAD, MN 56560



Fargo, ND • Grand Forks, ND • Alexandria, MN
701.280.0100 • 701.775.3394 • 320.846.0100

IMAGE GROUP INC., Architecture & Interiors
OBERMILLER NELSON ENGINEERING, Mechanical Engineers
MBN ENGINEERING, Electrical Engineers



Drawing Title
**FIRST FLOOR
FIRE PROTECTION
DEMOLITION PLAN**

VA Project No.
437-13-105

Building No.
1, 9, 46

Contract No.
VA263-P-1217
VA263-C-

AutoCAD File Name
2012227-FP-2.dwg

Project Title
FARGO VA HEALTH CARE SYSTEM
REPLACE SELECTED SPRINKLER MAINS PHASE 2

Designed By
JP

Checked By
JP

Drawn By
NH

Location
FARGO VA HEALTH CARE SYSTEM
FARGO, ND

Date
February 5, 2013

Drawing No.
FP2

Dwg. 9 of 16

Department of
Veterans Affairs



FIRE PROTECTION
DEMOLITION NOTES:

- A. DEMOLITION DRAWINGS ARE DIAGRAMMATIC ONLY AND ARE BASED ON FIELD OBSERVATION AND EXISTING RECORD DRAWINGS. CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS PRIOR TO BEGINNING WORK AND NOTIFY THE ARCHITECT/ ENGINEER OF ANY DISCREPANCIES BETWEEN THE "AS-BUILT" CONDITIONS AND THESE DRAWINGS.
- B. THIS CONTRACTOR IS RESPONSIBLE FOR REMOVAL AND RE-INSTALLING OF EXISTING CEILING TILE NOT REMOVED BY THE GENERAL CONTRACTOR FOR THE DEMOLITION OF EXISTING FIRE PROTECTION PIPING, SPRINKLER HEADS, EQUIPMENT, ETC. VERIFY WITH ARCHITECTURAL PLANS FOR CEILING WORK BY THE GENERAL CONTRACTOR. ANY CEILING TILE OR GRID DAMAGED DURING CONSTRUCTION SHALL BE REPLACED WITH NEW BY THIS CONTRACTOR.
- C. THIS CONTRACTOR SHALL OPEN ALL WALLS AND/OR CEILINGS FOR DEMOLITION OF EXISTING FIRE PROTECTION PIPING, SPRINKLER HEADS, EQUIPMENT, ETC. AS REQUIRED.
- D. THIS CONTRACTOR IS RESPONSIBLE FOR PATCHING ALL HOLES/WALLS AND OR CEILINGS FROM DEMOLISHED FIRE PROTECTION PIPING, SPRINKLER HEADS, EQUIPMENT, ETC. IN FLOORS, WALLS, AND CEILINGS TO MATCH EXISTING.

DISCONNECT AND REMOVE EXISTING SPRINKLER PIPING. PREPARE REMAINING PIPING AND SPRINKLER HEADS FOR RE-CONNECTION.

DISCONNECT AND REMOVE EXISTING ZONE VALVE WITH SUPERVISORY SWITCH, FLOW SWITCH, TEST AND DRAIN VALVE, AND SIGHT GLASS. PREPARE REMAINING PIPING FOR RE-CONNECTION. THE EXISTING ZONE VALVE & SUPERVISORY SWITCH SHALL BE SAVED FOR RE-INSTALLATION.

GENERAL NOTES:

1. THE GENERAL CONTRACTOR IS REMOVING CEILING TILE AND GRID IN AREAS OF PIPE REPLACEMENT. RELOCATE AND REINSTALL EXISTING CEILING DIFFUSERS AND ALL GRILLES AS REQUIRED FOR WORK. SEE ARCHITECTURAL DRAWINGS FOR CEILING WORK.
2. ALL SPRINKLER MAINS BEING REMOVED SHALL BE REPLACED WITH THE SAME SIZE PIPE. SEE NEW PLANS FOR MAIN SIZES.

PHASING NOTES:

1. CONTRACTOR SHALL REPLACE SPRINKLER PIPING IN ALL AREAS DURING WEEKEND OR OVERTIME HOURS. WORK SPACES SHALL BE LEFT CLEAN AND USABLE BY THE END OF EACH SHIFT TO ALLOW STAFF USE OF AREAS DURING NORMAL BUSINESS HOURS. WORK IN MECHANICAL SPACES MAY BE COMPLETED DURING NORMAL BUSINESS HOURS.
2. COMPLETE WORK ON ONE SPRINKLER ZONE AT A TIME ON EACH FLOOR. THE SYSTEM SHALL BE FILLED BY THE END OF EACH SHIFT IN ORDER TO MAINTAIN AN OPERATIONAL SYSTEM. AT THE CONTRACTOR'S OPTION, FIRE WATCH SHALL BE MAINTAINED BY THE CONTRACTOR FOR NON-OPERATIONAL ZONES FOR SHORT PERIODS OF TIME IN ORDER TO EXPEDITE WORK IN CERTAIN AREAS.
3. REFER TO INDIVIDUAL PLAN NOTES FOR PHASING OF CRITICAL AREAS.

1 FOURTH FLOOR FIRE PROTECTION DEMOLITION PLAN
FP3 1/16"=1'-0"



Dept. of Veterans Affairs
Medical Center
2101 Elm Street North
Fargo, ND 58102




IMAGE GROUP INC.
403 CENTER AVENUE, SUITE 300
MOORHEAD, MN 56560



ONE
Fargo, ND • Grand Forks, ND • Alexandria, MN
701.280.0100 • 701.775.3394 • 320.846.0100

IMAGE GROUP INC., Architecture & Interiors
OBERMILLER NELSON ENGINEERING, Mechanical Engineers
MBN ENGINEERING, Electrical Engineers



Drawing Title
**FOURTH FLOOR
FIRE PROTECTION
DEMOLITION PLAN**

VA Project No.
437-13-105

Building No.
1, 9, 46

Contract No.
VA263-P-1217
VA263-C-

AutoCAD File Name
2012227-FP-3.dwg

Project Title
FARGO VA HEALTH CARE SYSTEM
REPLACE SELECTED SPRINKLER MAINS PHASE 2

Designed By
JP

Checked By
JP

Drawn By
NH



Location
FARGO VA HEALTH CARE SYSTEM
FARGO, ND

Date
February 5, 2013

Drawing No.
FP3

Dwg. 10 of 16


Department of
Veterans Affairs



- FIRE PROTECTION NOTES:**
- CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS PRIOR TO BEGINNING WORK AND NOTIFY THE ARCHITECT/ENGINEER OF ANY DISCREPANCIES BETWEEN THE "AS-BUILT" CONDITIONS AND THESE DRAWINGS.
 - COORDINATE ALL FIRE PROTECTION INSTALLATION WITH GENERAL PLUMBING, VENTILATION, AND ELECTRICAL CONTRACTORS. INSTALL ALL FIRE PROTECTION PIPING AS HIGH AS POSSIBLE. PROVIDE ALL NECESSARY OFFSETS (DIPS AND RISERS) TO KEEP FIRE PROTECTION PIPING TIGHT TO THE STRUCTURE OR DUCTWORK ABOVE. OFFSET FIRE PROTECTION PIPING TO AVOID BEAMS.
 - ALL FIRE PROTECTION WORK SHALL ADHERE TO CURRENT NFPA 13 STANDARDS.
 - FIRE PROTECTION PIPING AND SPRINKLER HEADS ARE SHOWN FOR REFERENCE ONLY.
 - SPRINKLER HEADS IN LAY-IN-TILE CEILINGS SHALL BE LOCATED IN THE CENTER OF TILE.
 - REFER TO AND COORDINATE WITH THE ARCHITECTURAL PLANS FOR CEILING TYPES, HEIGHTS, SOFFIT AREAS, AND ELEVATIONS FOR INSTALLATION OF NEW FIRE PROTECTION PIPING, SPRINKLER HEADS, EQUIPMENT, ETC.
 - THIS CONTRACTOR SHALL OPEN ALL EXISTING WALLS AND/OR CEILINGS FOR INSTALLATION OF NEW FIRE PROTECTION PIPING, SPRINKLER HEADS, EQUIPMENT, ETC. AS REQUIRED. PATCH WALLS AND/OR CEILINGS TO MATCH EXISTING. FIRE CAULK ALL PIPING PENETRATIONS THROUGH EXISTING WALLS. FIRE CAULK ALL PIPING PENETRATIONS THROUGH EXISTING WALLS.
 - MAINTAIN 3'-0" CLEAR SPACE IN FRONT OF ALL ELECTRICAL, CONTROL, AND ACCESS PANELS FOR ACCESSIBILITY.
 - ALL AREAS OF WORK SHALL BE LEFT ACCESSIBLE AT THE END OF EVERY WORK DAY. SPRINKLER SYSTEM SHALL BE FULLY OPERATIONAL AT THE END OF EACH WORK DAY UNLESS FIRE WATCH IS PROVIDED.
 - VERIFY NEW FIRE PROTECTION INSTALLATION WITH EXISTING STRUCTURE, DUCTWORK, PIPING, LIGHTS, CONDUIT, FURNITURE, ETC. PRIOR TO BEGING. NO ADDITIONAL COMPENSATION SHALL BE ALLOWED ON THIS BASIS.
 - PROVIDE A NEW 1-INCH CONNECTION TO ALL EXISTING SPRINKLER HEADS CONNECTED TO THE MAINS BEING REPLACED.
 - PRIOR TO PIPING REPLACEMENT, FIELD VERIFY EXISTING PIPE SIZES. FOR ANY DEVIATIONS FROM THE SIZES LISTED ON PLAN, PROVIDE THE APPROPRIATE SIZE FITTINGS AND PIPING TO MATCH THE EXISTING SIZE PIPING ON SITE.
 - THIS CONTRACTOR IS RESPONSIBLE FOR REMOVAL AND RE-INSTALLING OF EXISTING CEILING TILE NOT REMOVED BY THE GENERAL CONTRACTOR FOR THE INSTALLATION OF NEW FIRE PROTECTION PIPING, SPRINKLER HEADS, EQUIPMENT, ETC. VERIFY WITH ARCHITECTURAL PLANS FOR CEILING WORK BY THE GENERAL CONTRACTOR. ANY CEILING TILE OR GRID DAMAGED DURING CONSTRUCTION SHALL BE REPLACED WITH NEW BY THIS CONTRACTOR.
 - ALL EXPOSED SPRINKLER PIPING SHALL BE PAINTED RED TO MATCH EXISTING EXPOSED PIPING AT THE VA.
- 1 CONTRACTOR SHALL RE-INSTALL EXISTING ZONE VALVE WITH SUPERVISORY SWITCH. CONTRACTOR SHALL SUPPLY AND INSTALL NEW FLOW SWITCH, PRESSURE GAUGE AND NEW TEST AND DRAIN VALVE. REFER TO 2/FP4 FOR MORE INFORMATION.
- 2 NEW SPRINKLER PIPE. INSTALL PIPING AS HIGH AS POSSIBLE.

- GENERAL NOTES:**
- ALL PIPING PENETRATIONS THRU CORRIDOR WALLS AND FIRE AND SMOKE BARRIERS SHALL BE FIRE STOPPED.

- PHASING NOTES:**
- CONTRACTOR SHALL REPLACE SPRINKLER PIPING IN ALL AREAS DURING WEEKEND OR OVERTIME HOURS. WORK SPACES SHALL BE LEFT CLEAN AND USABLE BY THE END OF EACH SHIFT TO ALLOW STAFF USE OF AREAS DURING NORMAL BUSINESS HOURS. WORK IN MECHANICAL SPACES MAY BE COMPLETED DURING NORMAL BUSINESS HOURS.
 - COMPLETE WORK ON ONE SPRINKLER ZONE AT A TIME ON EACH FLOOR. THE SYSTEM SHALL BE FILLED BY THE END OF EACH SHIFT IN ORDER TO MAINTAIN AN OPERATIONAL SYSTEM. AT THE CONTRACTOR'S OPTION, FIRE WATCH SHALL BE MAINTAINED BY THE CONTRACTOR FOR NON-OPERATIONAL ZONES FOR SHORT PERIODS OF TIME IN ORDER TO EXPEDITE WORK IN CERTAIN AREAS.
 - REFER TO INDIVIDUAL PLAN NOTES FOR PHASING OF CRITICAL AREAS.



1
FP4 BASEMENT FIRE PROTECTION REMODEL PLAN
1/16"=1'-0"



Dept. of Veterans Affairs
Medical Center
2101 Elm Street North
Fargo, ND 58102




IMAGE GROUP INC.
403 CENTER AVENUE, SUITE 300
MOORHEAD, MN 56560



Fargo, ND • Grand Forks, ND • Alexandria, MN
701.280.0100 • 701.775.3394 • 320.844.0100

IMAGE GROUP INC., Architecture & Interiors
OBERMILLER NELSON ENGINEERING, Mechanical Engineers
MBN ENGINEERING, Electrical Engineers



Drawing Title
**BASEMENT
FIRE PROTECTION
REMODEL PLAN**

VA Project No.
437-13-105

Building No.
1, 9, 46

Contract No.
VA263-P-1217
VA263-C-

AutoCAD File Name
2012227-FP-4.dwg

Project Title
FARGO VA HEALTH CARE SYSTEM
REPLACE SELECTED SPRINKLER MAINS PHASE 2

Designed By
JP

Location
FARGO VA HEALTH CARE SYSTEM
FARGO, ND

Checked By
JP

Location
FARGO VA HEALTH CARE SYSTEM
FARGO, ND

Drawn By
NH

Location
FARGO VA HEALTH CARE SYSTEM
FARGO, ND

Date
February 5, 2013

Drawing No.
FP4

Dwg. 11 of 16



FIRE PROTECTION NOTES:

- A. CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS PRIOR TO BEGINNING WORK AND NOTIFY THE ARCHITECT/ENGINEER OF ANY DISCREPANCIES BETWEEN THE "AS-BUILT" CONDITIONS AND THESE DRAWINGS.
- B. COORDINATE ALL FIRE PROTECTION INSTALLATION WITH GENERAL PLUMBING, VENTILATION, AND ELECTRICAL CONTRACTORS. INSTALL ALL FIRE PROTECTION PIPING AS HIGH AS POSSIBLE. PROVIDE ALL NECESSARY OFFSETS (DIPS AND RISERS) TO KEEP FIRE PROTECTION PIPING TIGHT TO THE STRUCTURE OR DUCTWORK ABOVE. OFFSET FIRE PROTECTION PIPING TO AVOID BEAMS.
- C. ALL FIRE PROTECTION WORK SHALL ADHERE TO CURRENT NFPA 13 STANDARDS.
- D. FIRE PROTECTION PIPING AND SPRINKLER HEADS ARE SHOWN FOR REFERENCE ONLY.
- E. SPRINKLER HEADS IN LAY-IN-TILE CEILINGS SHALL BE LOCATED IN THE CENTER OF TILE.
- F. REFER TO AND COORDINATE WITH THE ARCHITECTURAL PLANS FOR CEILING TYPES, HEIGHTS, SOFFIT AREAS, AND ELEVATIONS FOR INSTALLATION OF NEW FIRE PROTECTION PIPING, SPRINKLER HEADS, EQUIPMENT, ETC.
- G. THIS CONTRACTOR SHALL OPEN ALL EXISTING WALLS AND/OR CEILINGS FOR INSTALLATION OF NEW FIRE PROTECTION PIPING, SPRINKLER HEADS, EQUIPMENT, ETC. AS REQUIRED. PATCH WALLS AND/OR CEILINGS TO MATCH EXISTING. FIRE CAULK ALL PIPING PENETRATIONS THROUGH EXISTING WALLS. FIRE CAULK ALL PIPING PENETRATIONS THROUGH EXISTING WALLS.
- H. MAINTAIN 3'-0" CLEAR SPACE IN FRONT OF ALL ELECTRICAL, CONTROL, AND ACCESS PANELS FOR ACCESSIBILITY.
- I. ALL AREAS OF WORK SHALL BE LEFT ACCESSIBLE AT THE END OF EVERY WORK DAY. SPRINKLER SYSTEM SHALL BE FULLY OPERATIONAL AT THE END OF EACH WORK DAY UNLESS FIRE WATCH IS PROVIDED.
- J. VERIFY NEW FIRE PROTECTION INSTALLATION WITH EXISTING STRUCTURE, DUCTWORK, PIPING, LIGHTS, CONDUIT, FURNITURE, ETC. PRIOR TO BEGING. NO ADDITIONAL COMPENSATION SHALL BE ALLOWED ON THIS BASIS.
- K. PROVIDE A NEW 1-INCH CONNECTION TO ALL EXISTING SPRINKLER HEADS CONNECTED TO THE MAINS BEING REPLACED.
- L. PRIOR TO PIPING REPLACEMENT, FIELD VERIFY EXISTING PIPE SIZES. FOR ANY DEVIATIONS FROM THE SIZES LISTED ON PLAN, PROVIDE THE APPROPRIATE SIZE FITTINGS AND PIPING TO MATCH THE EXISTING SIZE PIPING ON SITE.
- M. THIS CONTRACTOR IS RESPONSIBLE FOR REMOVAL AND RE-INSTALLING OF EXISTING CEILING TILE NOT REMOVED BY THE GENERAL CONTRACTOR FOR THE INSTALLATION OF NEW FIRE PROTECTION PIPING, SPRINKLER HEADS, EQUIPMENT, ETC. VERIFY WITH ARCHITECTURAL PLANS FOR CEILING WORK BY THE GENERAL CONTRACTOR. ANY CEILING TILE OR GRID DAMAGED DURING CONSTRUCTION SHALL BE REPLACED WITH NEW BY THIS CONTRACTOR.
- N. ALL EXPOSED SPRINKLER PIPING SHALL BE PAINTED RED TO MATCH EXISTING EXPOSED PIPING AT THE VA.
1. CONTRACTOR SHALL RE-INSTALL EXISTING ZONE VALVE WITH SUPERVISORY SWITCH. CONTRACTOR SHALL SUPPLY AND INSTALL NEW FLOW SWITCH, PRESSURE GAUGE AND NEW TEST AND DRAIN VALVE. REFER TO 2/FP4 FOR MORE INFORMATION.
2. NEW SPRINKLER PIPE. INSTALL PIPING AS HIGH AS POSSIBLE.
3. WORK IN OUTLINED AREA REMOVED UNDER DEDUCT ALTERNATE NO. 1.
4. COORDINATE SCHEDULING OF WORK IN THIS AREA WITH PROJECT ENGINEER. DEMOLITION AND REPLACEMENT SHALL BE DONE DURING WEEKEND AND OVERTIME HOURS. EXISTING FURNISHINGS AND EQUIPMENT SHALL NOT BE MOVED. CONTRACTOR MUST COVER, PROTECT AND WORK AROUND THESE ITEMS. AFFECTED AREAS SHALL BE LEFT CLEAN AND USABLE AT THE END OF EACH SHIFT TO ALLOW USE DURING NORMAL BUSINESS HOURS.

GENERAL NOTES:

1. ALL PIPING PENETRATIONS THRU CORRIDOR WALLS AND FIRE AND SMOKE BARRIERS SHALL BE FIRE STOPPED.

PHASING NOTES:

1. CONTRACTOR SHALL REPLACE SPRINKLER PIPING IN ALL AREAS DURING WEEKEND OR OVERTIME HOURS. WORK SPACES SHALL BE LEFT CLEAN AND USABLE BY THE END OF EACH SHIFT TO ALLOW STAFF USE OF AREAS DURING NORMAL BUSINESS HOURS. WORK IN MECHANICAL SPACES MAY BE COMPLETED DURING NORMAL BUSINESS HOURS.
2. COMPLETE WORK ON ONE SPRINKLER ZONE AT A TIME ON EACH FLOOR. THE SYSTEM SHALL BE FLEED BY THE END OF EACH SHIFT IN ORDER TO MAINTAIN AN OPERATIONAL SYSTEM. AT THE CONTRACTOR'S OPTION, FIRE WATCH SHALL BE MAINTAINED BY THE CONTRACTOR FOR NON-OPERATIONAL ZONES FOR SHORT PERIODS OF TIME IN ORDER TO EXPEDITE WORK IN CERTAIN AREAS.
3. REFER TO INDIVIDUAL PLAN NOTES FOR PHASING OF CRITICAL AREAS.



1 FIRST FLOOR FIRE PROTECTION REMODEL PLAN
FP5 1/16"=1'-0"



Dept. of Veterans Affairs
Medical Center
2101 Elm Street North
Fargo, ND 58102




IMAGE GROUP INC.
403 CENTER AVENUE, SUITE 300
MOORHEAD, MN 56560



Fargo, ND • Grand Forks, ND • Alexandria, MN
701.280.8500 • 701.775.3394 • 320.846.0300

IMAGE GROUP INC., Architecture & Interiors
OBERMILLER NELSON ENGINEERING, Mechanical Engineers
MBN ENGINEERING, Electrical Engineers



Drawing Title

FIRST FLOOR
FIRE PROTECTION
REMODEL PLAN

VA Project No.
437-13-105

Building No.
1, 9, 46

Contract No.
VA263-P-1217
VA263-C-

AutoCAD File Name
2012227-FP-5.dwg

Project Title

FARGO VA HEALTH CARE SYSTEM
REPLACE SELECTED SPRINKLER MAINS PHASE 2

Designed By
JP

Checked By
JP

Drawn By
NH

Location
FARGO VA HEALTH CARE SYSTEM
FARGO, ND

Date

February 5, 2013

Drawing No.

FP5

Dwg. 12 of 16



FIRE PROTECTION NOTES:

- A. CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS PRIOR TO BEGINNING WORK AND NOTIFY THE ARCHITECT/ENGINEER OF ANY DISCREPANCIES BETWEEN THE "AS-BUILT" CONDITIONS AND THESE DRAWINGS.
- B. COORDINATE ALL FIRE PROTECTION INSTALLATION WITH GENERAL PLUMBING, VENTILATION, AND ELECTRICAL CONTRACTORS. INSTALL ALL FIRE PROTECTION PIPING AS HIGH AS POSSIBLE. PROVIDE ALL NECESSARY OFFSETS (DIPS AND RISERS) TO KEEP FIRE PROTECTION PIPING TIGHT TO THE STRUCTURE OR DUCTWORK ABOVE. OFFSET FIRE PROTECTION PIPING TO AVOID BEAMS.
- C. ALL FIRE PROTECTION WORK SHALL ADHERE TO CURRENT NFPA 13 STANDARDS.
- D. FIRE PROTECTION PIPING AND SPRINKLER HEADS ARE SHOWN FOR REFERENCE ONLY.
- E. SPRINKLER HEADS IN LAY-IN-TILE CEILINGS SHALL BE LOCATED IN THE CENTER OF TILE.
- F. REFER TO AND COORDINATE WITH THE ARCHITECTURAL PLANS FOR CEILING TYPES, HEIGHTS, SOFFIT AREAS, AND ELEVATIONS FOR INSTALLATION OF NEW FIRE PROTECTION PIPING, SPRINKLER HEADS, EQUIPMENT, ETC.
- G. THIS CONTRACTOR SHALL OPEN ALL EXISTING WALLS AND/OR CEILINGS FOR INSTALLATION OF NEW FIRE PROTECTION PIPING, SPRINKLER HEADS, EQUIPMENT, ETC. AS REQUIRED. PATCH WALLS AND/OR CEILINGS TO MATCH EXISTING. FIRE CAULK ALL PIPING PENETRATIONS THROUGH EXISTING WALLS. FIRE CAULK ALL PIPING PENETRATIONS THROUGH EXISTING WALLS.
- H. MAINTAIN 3'-0" CLEAR SPACE IN FRONT OF ALL ELECTRICAL, CONTROL, AND ACCESS PANELS FOR ACCESSIBILITY.
- I. ALL AREAS OF WORK SHALL BE LEFT ACCESSIBLE AT THE END OF EVERY WORK DAY. SPRINKLER SYSTEM SHALL BE FULLY OPERATIONAL AT THE END OF EACH WORK DAY UNLESS FIRE WATCH IS PROVIDED.
- J. VERIFY NEW FIRE PROTECTION INSTALLATION WITH EXISTING STRUCTURE, DUCTWORK, PIPING, LIGHTS, CONDUIT, FURNITURE, ETC. PRIOR TO BEGING. NO ADDITIONAL COMPENSATION SHALL BE ALLOWED ON THIS BASIS.
- K. PROVIDE A NEW 1-INCH CONNECTION TO ALL EXISTING SPRINKLER HEADS CONNECTED TO THE MAINS BEING REPLACED.
- L. PRIOR TO PIPING REPLACEMENT, FIELD VERIFY EXISTING PIPE SIZES. FOR ANY DEVIATIONS FROM THE SIZES LISTED ON PLAN, PROVIDE THE APPROPRIATE SIZE FITTINGS AND PIPING TO MATCH THE EXISTING SIZE PIPING ON SITE.
- M. THIS CONTRACTOR IS RESPONSIBLE FOR REMOVAL AND RE-INSTALLING OF EXISTING CEILING TILE NOT REMOVED BY THE GENERAL CONTRACTOR FOR THE INSTALLATION OF NEW FIRE PROTECTION PIPING, SPRINKLER HEADS, EQUIPMENT, ETC. VERIFY WITH ARCHITECTURAL PLANS FOR CEILING WORK BY THE GENERAL CONTRACTOR. ANY CEILING TILE OR GRID DAMAGED DURING CONSTRUCTION SHALL BE REPLACED WITH NEW BY THIS CONTRACTOR.
- N. ALL EXPOSED SPRINKLER PIPING SHALL BE PAINTED RED TO MATCH EXISTING EXPOSED PIPING AT THE VA.

1. CONTRACTOR SHALL RE-INSTALL EXISTING ZONE VALVE WITH SUPERVISORY SWITCH. CONTRACTOR SHALL SUPPLY AND INSTALL NEW FLOW SWITCH, PRESSURE GAUGE AND NEW TEST AND DRAIN VALVE. REFER TO 2/FP4 FOR MORE INFORMATION.
2. NEW SPRINKLER PIPE. INSTALL PIPING AS HIGH AS POSSIBLE.
3. COMBINE PARALLEL SPRINKLER PIPING INTO 1 PIPE (IF POSSIBLE) DURING REPLACEMENT.

GENERAL NOTES:

1. ALL PIPING PENETRATIONS THRU CORRIDOR WALLS AND FIRE AND SMOKE BARRIERS SHALL BE FIRE STOPPED.

PHASING NOTES:

1. CONTRACTOR SHALL REPLACE SPRINKLER PIPING IN ALL AREAS DURING WEEKEND OR OVERTIME HOURS. WORK SPACES SHALL BE LEFT CLEAN AND USABLE BY THE END OF EACH SHIFT TO ALLOW STAFF USE OF AREAS DURING NORMAL BUSINESS HOURS. WORK IN MECHANICAL SPACES MAY BE COMPLETED DURING NORMAL BUSINESS HOURS.
2. COMPLETE WORK ON ONE SPRINKLER ZONE AT A TIME ON EACH FLOOR. THE SYSTEM SHALL BE FILLED BY THE END OF EACH SHIFT IN ORDER TO MAINTAIN AN OPERATIONAL SYSTEM. AT THE CONTRACTOR'S OPTION, FIRE WATCH SHALL BE MAINTAINED BY THE CONTRACTOR FOR NON-OPERATIONAL ZONES FOR SHORT PERIODS OF TIME IN ORDER TO EXPEDITE WORK IN CERTAIN AREAS.
3. REFER TO INDIVIDUAL PLAN NOTES FOR PHASING OF CRITICAL AREAS.



1 FOURTH FLOOR FIRE PROTECTION REMODEL PLAN
FP6 1/16"=1'-0"




Dept. of Veterans Affairs
Medical Center
2101 Elm Street North
Fargo, ND 58102

IMAGE GROUP INC.
403 CENTER AVENUE, SUITE 300
MOORHEAD, MN 56560

ONE
BUILDING SYSTEM CONSULTANTS
Fargo, ND • Grand Forks, ND • Alexandria, MN
701.280.0100 • 701.775.3394 • 320.846.0100

IMAGE GROUP INC., Architecture & Interiors
OBERMILLER NELSON ENGINEERING, Mechanical Engineers
MBN ENGINEERING, Electrical Engineers



Drawing Title
FOURTH FLOOR
FIRE PROTECTION
REMODEL PLAN

VA Project No.
437-13-105

Building No.
1, 9, 46

Contract No.
VA263-P-1217
VA263-C-

AutoCAD File Name
2012227-FP-6.dwg

Project Title
FARGO VA HEALTH CARE SYSTEM
REPLACE SELECTED SPRINKLER MAINS PHASE 2

Designed By
JP

Location
FARGO VA HEALTH CARE SYSTEM
FARGO, ND

Checked By
JP

Drawn By
NH

Date
February 5, 2013

Drawing No.
FP6

Dwg. 13 of 16

